

ADDENDUM NO. 1

TO: ALL PLAN HOLDERS

RE: TEXARKANA WATER UTILITIES
24" TRANSMISSION MAIN TO TN RD PUMP STATION

ADDENDUM DATE: September 15, 2025


BID DATE: September 17, 2025

The Plans, Specifications and Contract Documents for the above referenced project are hereby modified as follows:

1. A revised bid form is included in the contract documents. The items listed herein have been updated to the Bid Form (Pages P-3 through P-14):
 - a. Bid Item 18 – Clearing and Grubbing is added as a pay item.
 - b. Casing Pipe in Bid Items 2 & 3, shall be Steel (0.375" thickness).
 - c. Bid Item 6 – Included in this item, contractor shall perform hydroexcavation to confirm depth and tie-in locations for adjacent water main connections and fire hydrant tie-in.

ADDENDUM NO. 1 ISSUED BY:

A.L. FRANKS ENGINEERING



Jason C. Haley, P.E.
Project Manager

TEXARKANA WATER UTILITIES

24" TRANSMISSION MAIN TO TENNESSEE RD PUMP STATION

BID PROPOSAL - A

<u>ITEM</u>	<u>QTY/UNIT</u>	<u>DESCRIPTION</u>	<u>TOTAL PRICE</u>
1.	7,800 L.F.	Furnish and Install 24" PVC C-900 DR18 Vented Restraint-Joint Pipe and Fittings including Trench Excavation, Trench Shoring, Trench Blocking and Backfilling per plans and specifications for the unit price of _____ Dollars and _____ Cents/L.F.	\$ _____ \$ _____
2.	295 L.F.	Furnish and Install 24" PVC C-900 DR18 Vented Restraint-Joint Pipe with 36" Stiff Wall Manhole including Trench Excavation, Trench Shoring, Trench Blocking and Backfilling per plans and specifications for the unit price of _____ Dollars and _____ Cents/L.F.	\$ _____ \$ _____
3.	204 L.F.	Furnish and Install 24" PVC C-900 DR18 Restraint-Joint Vented Pipe by Trenching to include Trench Excavation, Trench Shoring, Trench Blocking and materials in accordance with the specifications for the unit price of _____ Dollars and _____ Cents/L.F.	\$ _____ \$ _____

BID PROPOSAL
(Cont'd)

<u>ITEM</u>	<u>QTY/UNIT</u>	<u>DESCRIPTION</u>	<u>TOTAL PRICE</u>
4.	3 EA.	Furnish and Install 24" Gate Valve including precast valve box, valve marker and blocking per plans and for the unit price of <div>_____ Dollars and</div> <div>_____ Cents/EA.</div>	\$ _____
5.	1 EA.	Furnish and Install 12" x 12" Tapping Saddle including tapping saddle, valve marker and blocking per plans and for the unit price of <div>_____ Dollars and</div> <div>_____ Cents/EA.</div>	\$ _____
6.	1 EA.	Furnish and Install 24" Water Main excavation, shoring, in accordance with plans for the unit price of <div>_____ Dollars and</div> <div>_____ Cents/EA.</div>	\$ _____

BID PROPOSAL
(Cont'd)

<u>ITEM</u>	<u>QTY/UNIT</u>	<u>DESCRIPTION</u>	<u>TOTAL PRICE</u>
7.	1 EA.	Install 2" air release/vacuum valve assembly including Labor, materials, and equipment for the water main In accordance with the plans and specifications unit price of _____ _____	\$ _____
8.	1 EA.	Install Fire Hydrant Assembly Blocking, labor, materials, and equipment With the plans and specifications _____ Dollars and _____ Cents/EA.	\$ _____ \$ _____
9.	1 L.S.	_____ _____ _____ _____ Dollars and _____ Cents/L.S.	\$ _____ \$ _____

BID PROPOSAL
(Cont'd)

<u>ITEM</u>	<u>QTY/UNIT</u>	<u>DESCRIPTION</u>	<u>TOTAL PRICE</u>
10.	1 L.S.	Perform Testing and Disinfection including sampling for the water main as shown in the plans and specifications for the lump sum price of _____ _____	\$ _____
11.	1 L.S.	Provide and Install Tracer Wire and Fiberglass water main marking as shown in the plans and specifications for the lump sum price of _____ _____ and _____ Cents/L.S.	\$ _____ \$ _____
12.	60 L.F.	Open Cut trenching and installation per plans and specifications for the lump sum price of _____ _____ Dollars and _____ Cents/LF.	\$ _____ \$ _____
13.	1 L.S.	_____ _____ plans and specifications for the lump sum price of _____ _____ Dollars and _____ Cents/L.S.	\$XXXXXX \$ _____

BID PROPOSAL
(Cont'd)

<u>ITEM</u>	<u>QTY/UNIT</u>	<u>DESCRIPTION</u>	<u>TOTAL PRICE</u>
14.	500 L.F.	Provide, Install and Maintain Silt Fence per Approved Stormwater Pollution Prevention Plan for the lump sum price of _____	\$ _____
15.	100 S.Y.	Provide & Install 12" Rock Fabric on Slope / Creek Stabilization measure _____ Dollars and _____ Cents/S.Y. \$ _____	\$ _____
16.	20 L.F.	Reinforced Concrete Pressure Rated Pipe (PVC DR-18) Trench, including bedding, compaction, fittings, temporary plugging, in accordance with the plans and specifications _____ Dollars and _____ Cents/L.F. \$ _____	\$ _____

17.	1 L.S.	Mobilization including preparatory work and operations, including but not limited to, movement of personnel, equipment, supplies, and incidentals to the project site for the lump sum price of	_____ Dollars and _____ Cents/L.S.	\$ _____
18.	1 L.S.	Perform Clearing and Grubbing to include _____ Debris as required for installation of the _____ equipment, and labor for the lump sum _____	_____ _____	\$ _____ \$ _____ =====
			PROPOSAL A	\$ _____

- NOTES:**
- 1) Owner will review and make _____ Budget and comparison of Bid Proposals A and B.
 - 2) Miscellaneous items, directed _____ specifically listed but required to complete the proposed improvements to a complete _____ all be included in the Bid under the most appropriate Bid Item.
 - 3) Time required to complete _____ 30 _____ calendar days.
 - 4) Contractor is to perform _____ elements of the Storm Water Pollution Prevention Plan found in Exhibit "A" of the Technical Specs.
 - 5) Contractor is to _____ complete abandonment of all existing mains unless otherwise noted.

TEXARKANA WATER UTILITIES

24" TRANSMISSION MAIN TO TENNESSEE RD PUMP STATION

BID PROPOSAL - B

<u>ITEM</u>	<u>QTY/UNIT</u>	<u>DESCRIPTION</u>	<u>TOTAL PRICE</u>
1.	7,800 L.F.	Furnish and Install 24" Ductile Iron Pipe (Class 250) Restraint-Joint and Fittings including Trench Excavation, Labor, equipment, blocking and Backfilling per plans and specifications for the unit price of <div>_____ Dollars and</div> <div>_____ Cents/L.F.</div>	<div>\$ _____</div> <div>\$ _____</div>
2.	295 L.F.	Furnish and Install 24" Ductile Iron Pipe (Class 250) Restraint-Joint Pipe with 36" Steel Bells including Trench Excavation, Labor, equipment, blocking and Backfilling per plans and specifications for the unit price of <div>_____ Dollars and</div> <div>_____ Cents/L.F.</div>	<div>\$ _____</div> <div>\$ _____</div>
3.	204 L.F.	Furnish and Install 24" Ductile Iron Pipe (Class 250) Restraint-Joint Pipe by Trenching to include materials in accordance with the specifications for the unit price of <div>_____ Dollars and</div> <div>_____ Cents/L.F.</div>	<div>\$ _____</div> <div>\$ _____</div>

BID PROPOSAL
(Cont'd)

<u>ITEM</u>	<u>QTY/UNIT</u>	<u>DESCRIPTION</u>	<u>TOTAL PRICE</u>
4.	3 EA.	Furnish and Install 24" Gate Valve including precast valve box, valve marker and blocking per plans and for the unit price of <div>_____ Dollars and</div> <div>_____ Cents/EA.</div>	\$ _____
5.	1 EA.	Furnish and Install 12" x 12" Tapping Saddle including tapping saddle, valve marker and blocking per plans and for the unit price of <div>_____ Dollars and</div> <div>_____ Cents/EA.</div>	\$ _____
6.	1 EA.	Furnish and Install 24" Water Main excavation, shoring, in accordance with plans for the unit price of <div>_____ Dollars and</div> <div>_____ Cents/EA.</div>	\$ _____

BID PROPOSAL
(Cont'd)

<u>ITEM</u>	<u>QTY/UNIT</u>	<u>DESCRIPTION</u>	<u>TOTAL PRICE</u>
7.	1 EA.	Install 2" air release/vacuum valve assembly including Labor, materials, and equipment for the water main In accordance with the plans and specifications unit price of _____ _____	\$ _____
8.	1 EA.	Install Fire Hydrant Assembly Blocking, labor, materials, and equipment With the plans and specifications _____ Dollars and _____ Cents/EA.	\$ _____ \$ _____
9.	1 L.S.	_____ Seeding of all disturbed _____ the Stormwater Pollution _____ and specifications for _____ Dollars and _____ Cents/L.S.	\$ _____ \$ _____

BID PROPOSAL
(Cont'd)

<u>ITEM</u>	<u>QTY/UNIT</u>	<u>DESCRIPTION</u>	<u>TOTAL PRICE</u>
10.	1 L.S.	Perform Testing and Disinfection for the water main Sampling taps per plans and specifications for the lump sum price of _____	\$ _____
11.	1 L.S.	Provide and Install Tracer Wire Fiberglass water main marker _____ down in the plans and specifications of _____ and _____ Cents/L.S.	\$ _____ \$ _____
12.	60 L.F.	Open Cut _____ per plans _____ price of _____ Dollars and _____ Cents/LF.	\$ _____ \$ _____
13.	1 L.S.	_____ plans and specifications price of _____ Dollars and _____ Cents/L.S.	\$XXXXXX \$ _____

BID PROPOSAL
(Cont'd)

<u>ITEM</u>	<u>QTY/UNIT</u>	<u>DESCRIPTION</u>	<u>TOTAL PRICE</u>
14.	500 L.F.	Provide, Install and Maintain Silt Fence per Approved Stormwater Pollution Prevention Plan for the lump sum price of _____	\$ _____
15.	100 S.Y.	Provide & Install 12" Rock Fabric on Slope / Creek Stabilization measures _____ Dollars and _____ Cents/S.Y. \$ _____	\$ _____
16.	20 L.F.	Provide and install 12" Pressure Rated Pipe (PVC DR-18) including compaction, fittings, temporary plugging, in accordance with the plans and specifications _____ Dollars and _____ Cents/L.F. \$ _____	\$ _____

17.	1 L.S.	Mobilization including preparatory work and operations, including but not limited to, movement of personnel, equipment, supplies, and incidentals to the project site for the lump sum price of	_____ Dollars and _____ Cents/L.S.	\$ _____
18.	1 L.S.	Perform Clearing and Grubbing to include removal of _____ Debris as required for installation of the water _____ equipment, and labor for the lump sum price of _____	_____ \$ _____	\$ _____
PROPOSAL B				\$ _____

- NOTES:**
- 1) Owner will review and make award based on comparison of Bid Proposals A and B.
 - 2) Miscellaneous items, directed by the Engineer, specifically listed but required to complete the proposed improvements to a complete project, shall be included in the Bid under the most appropriate Bid Item.
 - 3) Time required to complete the project shall be _____ calendar days.
 - 4) Contractor is to perform all items of the Storm Water Pollution Prevention Plan found in Exhibit "A" of the Technical Specs.
 - 5) Contractor is solely responsible for the abandonment of all existing mains unless otherwise noted.