

ADDENDUM NO. 2

TO: ALL PLAN HOLDERS

RE: CITY OF MAGNOLIA, ARKANSAS-NEW ELEVATED TANK


ADDENDUM DATE: March 30, 2026

The Plans, Specifications and Contract Documents for the above referenced project are hereby modified as follows:

- 1. Bid Date Revised: The Bid Opening Date will be postponed until Tuesday April 7, 2026 at City Hall in Magnolia at 2pm.**
- 2. Clarification: Geotechnical Report-Based on the information in the Geotechnical Report from ETTL, it appears that drilled piers or rammed aggregate piers may be necessary for foundation design. Final foundation and structural design by an Engineer licensed in the state of Arkansas shall be provided by the successful contractor during the submittal process.**

ADDENDUM NO. 2 ISSUED BY:

A.L. FRANKS ENGINEERING



Anthony L. (Andy) Franks, P.E.
Project Manager